

RESOLUTION NO. 262


AUTHORIZING PURCHASE OF TWO PICK-UP TRUCKS

WHEREAS, the East Wenatchee Water District is now leasing a 1976 Ford Courier for the purpose of reading water meters within the District, and,


WHEREAS, said lease expires on April 21, 1979, and

WHEREAS, due to the residual balance owing on said lease, which is approximately \$1,650.00 and wear, plus excessive mileage, it is believed deemed in the best interest of the District to terminate said lease and purchase outright a 1979 Datsun, and a 1979 G.M.C. half-ton truck, to be utilized for general maintenance and upkeep of the District. Said pick-ups were the lowest quotes received from the six dealers which submitted a bid. Written bids are on file in the District's office and will be retained for public inspection.

ADOPTED, this 12th day of March, 1979, by the BOARD OF COMMISSIONERS of the EAST WENATCHEE WATER DISTRICT, Douglas County, Washington at a regular meeting thereof.

  
\_\_\_\_\_  
J. Clyde Ballard, President

ATTEST:

  
\_\_\_\_\_  
Paul W. Blanchard, Secretary

/sr

RESOLUTION TO AMEND THE UNIFORM PLUMBING CODE, CURRENTLY ADOPTED EDITION

WHEREAS: The use of plastic piping has proven to be unsatisfactory as the building supply piping, and

WHEREAS: The Douglas County Building Department has jurisdiction over the entire plumbing system of a premises, and

WHEREAS: The Uniform Plumbing Code is designed for the protection of the public health, safety and welfare,

NOW THEREFORE BE IT RESOLVED: By the Board of County Commissioners of Douglas County, Washington to amend the Uniform Plumbing Code, currently adopted edition, as follows:

- 1) Amend Section 103 (K) to include mobile homes, factory-built housing and any structure designed for human occupancy under the definition of "Building", for the purposes of this Resolution.
- 2) Add to Section 1004 (a), Materials, the following: water pipe and fittings for use as the building supply piping from the water source and/or water meter to the building shall be galvanized steel pipe.
  - a.) When building supply comes into a building, under a concrete slab, the galvanized steel piping shall be wrapped with polyvinyl adhesive pipe wrap tape, or be factory-wrapped with an approved protective coating from a point two (2) feet outside the foundation to six (6) inches above the slab.
  - b.) For a building built with a crawl space, the building supply piping shall extend inside the foundation wall a minimum of two (2) feet. The connection of the galvanized steel piping to a copper water distribution system shall be at a point a minimum of six (6) inches above the ground level in the crawl space.
  - c.) When the building supply piping extends through a concrete wall and the piping will be embedded in the concrete, the pipe shall be wrapped with several layers of polyvinyl adhesive pipe wrap tape from a point six (6) inches outside the concrete wall to a point six (6) inches inside the concrete wall.
  - d.) When the building supply piping is serving a mobile home, the galvanized steel piping shall extend to a point under the mobile home, a minimum of one (1) foot within the outside dimension of the mobile home and the point of connection to the mobile home water distribution system shall be a minimum of six (6) inches above ground level under the mobile home.

- 3) Add to Section 1008 (a), Installation, Inspection, and Testing, the following:

The building supply piping shall be buried a minimum of thirty-six (36) inches below finish grade.

- 4) Add to 1008 (d), Inspection, the following:

The building supply piping shall not be covered or concealed until it first has been inspected, tested, and approved.