

ORIGINAL

RESOLUTION NO. 653

EMERGENCY RESOLUTION FOR MAIN REPLACEMENT 5TH ST NE
NORTH QUINCY AVE TO NORTH STARK AVE

WHEREAS, the East Wenatchee Water District has attempted to make repairs to the existing 6 inch old steel main on 5th St NE, and

WHEREAS, the District has repaired and replaced other steel main in this vicinity over the years, and

WHEREAS, the crew cannot adequately reconnect to the existing pipe due to its poor condition, and

WHEREAS, the watermain needs to continue to be replaced to the east and needs to connect into a suitable point and needs to be connected to watermain in adequate condition, and


WHEREAS, it is deemed to be in the best interest of the District to declare this extension project as an Emergency and proceed to procure approximately 1,300' of additional 8" ductile iron pipe material and associated parts and replace the existing steel pipe, and

WHEREAS, due to the condition of the old steel pipe and the severity of the leaks, there is a health and safety concern and there is not adequate time to have the project designed, competitively bid and completed before winter, therefore the Commissioners conclude it is an Emergency repair project, and


WHEREAS, it is in the best interest of the District to use its own crew to replace said waterline, and

NOW THEREFORE, BE IT HEREBY RESOLVED by the BOARD OF COMMISSIONERS of the EAST WENATCHEE WATER DISTRICT that the watermain replacement project on 5th ST NE between Quincy and Stark be deemed as an Emergency.

ADOPTED, this 15th day of October, 2014, by the BOARD OF COMMISSIONERS of the East Wenatchee Water District, Douglas County, Washington at a regular meeting thereof.


G. Brian Egan, President

ATTEST:


Mike McCourt, Secretary